



Product Certificate

Nr. 3397

SINTEF confirms that

Hunton Nativo Wood fiber Insulation

Complies with the requirements in EN 15101-1

Declared thermal conductivity, density 27 – 40 kg/m³: $\lambda_D = 0,038$ W/mK
Settlement under cyclic humidity, density 30 kg/m³ (open blow): **Class SH 20**
Settlement under vibrations, density 40 kg/m³ (cavity blow): **Class SC 0**

Reaction to fire according to EN 13501-1, density 23 – 55 kg/m³
with minimum 40 mm thickness: **Fire classification E**

Certificate holder:

Hunton Fiber AS

Niels Ødegaards gate 8
2810 Gjøvik

Manufacturer:

Hunton Isolasjon AS
Brennbakkvegen 15
2822 Bybrua

Issued 07.11.2018

Revised 26.01.2024

Valid until 01.04.2024 provided listed on www.sintefcertification.no

The manufacturing of the product is subject to factory production control in accordance with the provisions in EN ISO/IEC 17065.



.....
Anne-Jorunn Enstad
Certification Manager